

Certificate of Conformity

No. ESY 114387 0147 Rev. 00

Holder of Certificate: **Huawei Digital Power Technologies Co., Ltd.**
Office 01, 39th Floor, Block A
Antuoshan Headquarters Towers
33 Antuoshan 6th Road, Futian District
518043 Shenzhen
PEOPLE'S REPUBLIC OF CHINA

Product: **Converter
(PV Inverter)**

Model(s): **SUN2000-3K-LB0, SUN2000-3.68K-LB0,
SUN2000-4K-LB0, SUN2000-4.6K-LB0,
SUN5000-3K-LB0**

Parameters: See page 2

Applicable standards: VDE-AR-N 4105:2018
DIN VDE V 0124-100 (VDE V 0124-100):2020

This Certificate of Conformity confirms the compliance with the above listed standards on a voluntary basis. It refers only to the sample submitted to TÜV SÜD Product Service GmbH and does not certify the quality or safety of the serial products. It was issued according to TÜV SÜD Product Service certification program Photovoltaics and Grid Integration. For details see: www.tuvsud.com/ps-cert

Test report no.: 64290243007701

Date, 2024-12-12



(Billy Qiu)

Certificate of Conformity

No. ESY 114387 0147 Rev. 00

Parameters:

Model	SUN2000-3K-LB0 / SUN5000-3K-LB0	SUN2000-3.68K-LB0	SUN2000-4K-LB0	SUN2000-4.6K-LB0
PV terminal parameters				
Maximum PV voltage [V_{DC}]	600			
Rated voltage [V_{DC}]	360			
MPPT voltage range [V_{DC}]	40-560			
MPPT voltage range (full load) [V_{DC}]	120-480	140-480	155-480	180-530
Maximum input current [A_{DC}]	16/16			
Isc PV [A_{DC}]	20/20			
MPPT tracker number	2			
Maximum input power [W]	4500	5520	6000	6900
Grid terminal input/output parameters				
Rated input/output voltage [V_{AC}]	1P+N+PE, 230			
Rated input/output frequency [Hz]	50			
Rated output current [A_{AC}]	13.00	16.00	17.40	20.00
Maximum continuous input/output current [A_{AC}]	15.00	16.00	20.00	23.00
Rated output active power [W]	3000	3680	4000	4600
Maximum continuous input/output active power [W]	3300	3680	4400	4600
Maximum continuous input/output apparent power [VA]	3300	3680	4400	4600
Power factor range	0.8 under-excited to 0.8 over-excited			

Certificate of Conformity

No. ESY 114387 0147 Rev. 00

E.4 Unit certificate

Unit certificate		
Manufacturer	Huawei Digital Power Technologies Co.,Ltd.	
Power generation unit type	[PV Inverter]: SUN2000-3K-LB0, SUN2000-3.68K-LB0, SUN2000-4K-LB0, SUN2000-4.6K-LB0, SUN5000-3K-LB0 Remark: certified on representative model <u>SUN2000-4.6K-LB0</u> of family design products, results of the measurement of <u>SUN2000-4.6K-LB0</u> can be transferred to other models based on transferability rule of measurements in DIN VDE V 0124-100 (VDE V 0124-100):2020-06.	
Assessment values	max. active power P_{Emax}	4600 W (SUN2000-4.6K-LB0)
	max. apparent power S_{Emax}	4600 VA (SUN2000-4.6K-LB0)
	Rated voltage	1/N/PE~, 230V _{AC}
	Rated current (AC) I_r	20.0 A (SUN2000-4.6K-LB0)
	Initial short-circuit AC current I''_k	23.0 A (SUN2000-4.6K-LB0)
Network connection rule	VDE-AR-N 4105:2018-11 “Generators connected to the low-voltage distribution network” Technical minimum requirements for connection and parallel operation of power generation systems connected to the low-voltage network	
Test requirement	DIN VDE V 0124-100 (VDE V 0124-100):2020-06 “Network integration of power generation systems – Low voltage” Test requirements for power generation units intended for connection to and parallel operation on the low-voltage network	
Test report	64.290.24.30077.01 from 2024-11-12	
The above designated power generation unit meets the requirements of VDE-AR-N 4105:2018-11.		

Certificate of Conformity

No. ESY 114387 0147 Rev. 00

E.5 Test report "Network interactions" for power generation units with an input current > 75 A

Extract of the test report for power generation units "Determination of electrical properties"		
System manufacturer:	Huawei Digital Power Technologies Co.,Ltd. Office 01, 39th Floor, Block A, Antuoshan Headquarters Towers, 33 Antuoshan 6th Road, Futian District, 518043, Shenzhen, PEOPLE'S REPUBLIC OF CHINA	
Manufacturer indications:	Type of system	PV Inverter
	Max. active power $P_{E_{max}}$	3300 W (SUN2000-3K-LB0) 3680 W (SUN2000-3.68K-LB0) 4400 W (SUN2000-4K-LB0) 4600 W (SUN2000-4.6K-LB0) 3300 W (SUN5000-3K-LB0)
	Rated voltage	1/N/PE~, 230V _{AC}
	Measurement period:	From 2024-09-17 to 2024-11-01

Certificate of Conformity

No. ESY 114387 0147 Rev. 00

Rapid voltage changes	
Model	<u>SUN2000-3.68K-LB0</u>
Connection without provisions (regarding the primary energy carrier)	$K_i=0.498$
Most adverse case when switching between generator levels	$K_i=0.503$
Connection at nominal conditions (of the primary energy carrier)	$K_i=0.998$
Disconnection at rated power	$K_i=1.002$
Worst value of all switching operations	$K_{i\max}=1.002$

Rapid voltage changes	
Model	<u>SUN2000-4.6K-LB0</u>
Connection without provisions (regarding the primary energy carrier)	$K_i=0.499$
Most adverse case when switching between generator levels	$K_i=0.502$
Connection at nominal conditions (of the primary energy carrier)	$K_i=0.997$
Disconnection at rated power	$K_i=1.000$
Worst value of all switching operations	$K_{i\max}=1.000$

Flicker (<u>SUN2000-3.68K-LB0</u>)					
Network impedance angle Ψ_k	30°	50°	70°	85°	32°
Coefficient of system flicker C_Ψ (Maximum)					
L1	--	--	--	--	0.396

Flicker (<u>SUN2000-4.6K-LB0</u>)					
Network impedance angle Ψ_k	30°	50°	70°	85°	32°
Coefficient of system flicker C_Ψ (Maximum)					
L1	--	--	--	--	0.132

Certificate of Conformity

No. ESY 114387 0147 Rev. 00

Harmonics (≤ 16 A) (SUN2000-3.68K-LB0)												
Active power P/Pn[%]	0	10	20	30	40	50	60	70	80	90	100	Limit value
Ordinal number	A	A	A	A	A	A	A	A	A	A	A	A
2	0.026	0.020	0.028	0.029	0.037	0.047	0.058	0.068	0.076	0.086	0.105	1.080
3	0.095	0.033	0.041	0.031	0.025	0.028	0.033	0.043	0.052	0.065	0.066	2.300
4	0.005	0.004	0.012	0.015	0.010	0.010	0.014	0.014	0.016	0.018	0.023	0.430
5	0.056	0.080	0.014	0.012	0.009	0.006	0.008	0.006	0.007	0.005	0.006	1.140
6	0.004	0.007	0.004	0.007	0.009	0.011	0.013	0.010	0.010	0.011	0.013	0.300
7	0.228	0.087	0.216	0.107	0.016	0.019	0.031	0.037	0.037	0.042	0.047	0.770
8	0.002	0.002	0.005	0.006	0.009	0.013	0.015	0.012	0.013	0.013	0.018	0.230
9	0.144	0.166	0.144	0.118	0.036	0.029	0.040	0.042	0.046	0.050	0.051	0.400
10	0.003	0.003	0.005	0.005	0.006	0.009	0.010	0.009	0.009	0.008	0.010	0.184
11	0.076	0.098	0.066	0.112	0.057	0.031	0.035	0.038	0.037	0.041	0.041	0.330
12	0.003	0.004	0.006	0.006	0.005	0.007	0.008	0.009	0.010	0.009	0.011	0.153
13	0.041	0.047	0.066	0.086	0.071	0.042	0.042	0.045	0.043	0.044	0.043	0.210
14	0.002	0.003	0.005	0.007	0.005	0.006	0.008	0.009	0.010	0.010	0.013	0.131
15	0.019	0.044	0.047	0.052	0.071	0.048	0.043	0.047	0.046	0.046	0.044	0.150
16	0.002	0.003	0.005	0.007	0.005	0.006	0.007	0.008	0.008	0.008	0.009	0.115
17	0.009	0.021	0.025	0.033	0.063	0.050	0.042	0.045	0.044	0.044	0.042	0.132
18	0.003	0.002	0.006	0.007	0.006	0.006	0.007	0.008	0.008	0.008	0.010	0.102
19	0.013	0.005	0.031	0.030	0.049	0.050	0.042	0.044	0.044	0.044	0.041	0.118
20	0.002	0.002	0.005	0.006	0.006	0.006	0.007	0.008	0.008	0.008	0.009	0.092
21	0.020	0.017	0.019	0.023	0.034	0.049	0.042	0.043	0.042	0.043	0.041	0.107
22	0.002	0.002	0.004	0.005	0.005	0.006	0.006	0.007	0.008	0.008	0.008	0.084
23	0.024	0.016	0.007	0.012	0.022	0.043	0.040	0.040	0.041	0.042	0.040	0.098
24	0.002	0.002	0.004	0.005	0.005	0.006	0.006	0.007	0.008	0.008	0.009	0.077
25	0.026	0.024	0.024	0.015	0.019	0.036	0.038	0.038	0.039	0.041	0.040	0.090
26	0.002	0.002	0.004	0.004	0.004	0.006	0.006	0.007	0.008	0.008	0.009	0.071
27	0.027	0.027	0.020	0.018	0.019	0.027	0.034	0.034	0.037	0.039	0.038	0.083
28	0.002	0.002	0.004	0.004	0.004	0.005	0.006	0.006	0.007	0.007	0.008	0.066
29	0.028	0.031	0.021	0.014	0.017	0.019	0.030	0.030	0.033	0.037	0.036	0.078
30	0.002	0.002	0.004	0.003	0.003	0.005	0.005	0.006	0.007	0.007	0.008	0.061
31	0.028	0.033	0.030	0.014	0.013	0.013	0.024	0.025	0.029	0.033	0.034	0.073
32	0.002	0.002	0.004	0.003	0.003	0.004	0.005	0.005	0.006	0.006	0.007	0.058
33	0.027	0.035	0.029	0.023	0.011	0.012	0.019	0.021	0.025	0.030	0.031	0.068
34	0.002	0.002	0.004	0.003	0.003	0.004	0.005	0.005	0.005	0.006	0.007	0.054
35	0.027	0.036	0.032	0.028	0.013	0.014	0.015	0.017	0.021	0.026	0.028	0.064
36	0.002	0.002	0.004	0.004	0.003	0.004	0.004	0.004	0.005	0.006	0.007	0.051
37	0.027	0.036	0.036	0.026	0.015	0.015	0.012	0.014	0.018	0.022	0.026	0.061
38	0.002	0.002	0.003	0.004	0.003	0.004	0.004	0.004	0.004	0.005	0.006	0.048
39	0.026	0.036	0.031	0.024	0.016	0.015	0.010	0.011	0.013	0.018	0.022	0.058
40	0.002	0.002	0.004	0.004	0.003	0.004	0.004	0.004	0.004	0.004	0.006	0.046
THD	1.981%	1.611%	1.874%	1.490%	1.033%	0.944%	0.987%	1.067%	1.128%	1.230%	1.297%	5%
Remark: Iref=16 A.												

Certificate of Conformity

No. ESY 114387 0147 Rev. 00

Harmonics (>16 A and ≤75 A) (SUN2000-4.6K-LB0)												
Active power P/Pn[%]	0	10	20	30	40	50	60	70	80	90	100	Limit value
Ordinal number	I _h /I _{ref} [%]											[%]
2	0.124	0.115	0.132	0.159	0.222	0.290	0.338	0.401	0.455	0.532	0.559	8
3	0.486	0.296	0.172	0.126	0.131	0.178	0.231	0.307	0.367	0.440	0.526	21.6
4	0.021	0.054	0.074	0.063	0.048	0.071	0.071	0.094	0.105	0.122	0.119	4
5	0.285	0.342	0.063	0.048	0.032	0.035	0.037	0.026	0.026	0.047	0.101	10.7
6	0.016	0.017	0.030	0.038	0.054	0.056	0.048	0.045	0.052	0.081	0.091	2.67
7	1.174	0.950	0.825	0.178	0.091	0.151	0.187	0.196	0.217	0.313	0.365	7.2
8	0.012	0.029	0.024	0.034	0.061	0.064	0.061	0.060	0.064	0.098	0.107	2
9	0.729	0.305	0.737	0.274	0.136	0.204	0.202	0.238	0.254	0.349	0.387	3.8
10	0.014	0.018	0.026	0.028	0.040	0.046	0.042	0.042	0.038	0.062	0.060	1.6
11	0.374	0.699	0.522	0.368	0.150	0.178	0.188	0.192	0.201	0.273	0.306	3.1
12	0.015	0.021	0.036	0.028	0.029	0.039	0.044	0.045	0.047	0.059	0.047	1.33
13	0.191	0.210	0.270	0.412	0.204	0.218	0.218	0.219	0.219	0.271	0.295	2
14	0.011	0.023	0.036	0.027	0.027	0.039	0.043	0.050	0.051	0.063	0.053	-
15	0.085	0.250	0.210	0.372	0.228	0.218	0.226	0.222	0.215	0.261	0.283	-
16	0.011	0.013	0.031	0.028	0.027	0.034	0.037	0.042	0.044	0.053	0.043	-
17	0.039	0.119	0.196	0.289	0.242	0.215	0.222	0.221	0.209	0.241	0.252	-
18	0.013	0.018	0.031	0.031	0.027	0.034	0.038	0.042	0.044	0.049	0.041	-
19	0.062	0.116	0.101	0.201	0.246	0.213	0.219	0.219	0.210	0.236	0.242	-
20	0.011	0.013	0.027	0.032	0.028	0.035	0.040	0.042	0.043	0.049	0.042	-
21	0.097	0.037	0.089	0.129	0.241	0.211	0.216	0.219	0.208	0.228	0.234	-
22	0.011	0.012	0.026	0.027	0.030	0.032	0.038	0.042	0.040	0.043	0.036	-
23	0.117	0.122	0.107	0.104	0.210	0.199	0.206	0.212	0.204	0.219	0.220	-
24	0.010	0.012	0.025	0.023	0.028	0.029	0.036	0.039	0.041	0.044	0.036	-
25	0.126	0.105	0.052	0.099	0.174	0.189	0.197	0.206	0.203	0.211	0.217	-
26	0.010	0.012	0.021	0.022	0.028	0.029	0.035	0.039	0.038	0.042	0.038	-
27	0.134	0.126	0.073	0.080	0.130	0.168	0.181	0.197	0.195	0.198	0.202	-
28	0.011	0.013	0.019	0.020	0.025	0.027	0.032	0.038	0.039	0.040	0.034	-
29	0.136	0.157	0.137	0.061	0.089	0.149	0.163	0.181	0.188	0.191	0.194	-
30	0.010	0.013	0.020	0.019	0.021	0.026	0.031	0.035	0.037	0.039	0.036	-
31	0.136	0.160	0.136	0.063	0.063	0.121	0.139	0.163	0.175	0.174	0.179	-
32	0.010	0.012	0.020	0.017	0.019	0.023	0.026	0.033	0.035	0.036	0.034	-
33	0.134	0.171	0.129	0.077	0.061	0.102	0.119	0.146	0.163	0.161	0.169	-
34	0.010	0.012	0.019	0.016	0.018	0.022	0.026	0.030	0.033	0.033	0.032	-
35	0.132	0.167	0.148	0.082	0.070	0.080	0.096	0.126	0.148	0.145	0.156	-
36	0.010	0.012	0.019	0.015	0.018	0.020	0.022	0.027	0.031	0.030	0.031	-
37	0.131	0.188	0.153	0.076	0.076	0.066	0.080	0.109	0.135	0.127	0.141	-
38	0.009	0.011	0.020	0.016	0.017	0.019	0.020	0.023	0.029	0.025	0.028	-
39	0.129	0.170	0.138	0.080	0.077	0.054	0.058	0.086	0.117	0.112	0.126	-
40	0.011	0.013	0.021	0.016	0.018	0.018	0.020	0.022	0.027	0.023	0.026	-
THC/I _{ref}	1.612	1.434	1.369	0.899	0.729	0.797	0.863	0.953	1.014	1.190	1.293	23
PWHC/I _{ref}	2.287	2.906	2.527	2.563	2.770	2.840	3.034	3.292	3.393	3.560	3.692	23
Remark: I _{ref} =20 A.												

Certificate of Conformity

No. ESY 114387 0147 Rev. 00

E.6 Certificate of the network and system protection

Certificate of NS protection		
Manufacturer	Huawei Digital Power Technologies Co.,Ltd.	
Type of NS protection	Integrated NS protection	
Central NS protection	☐	
Integrated NS protection	☒	Assigned to power generation unit of type: <u>SUN2000-3K-LB0, SUN2000-3.68K-LB0, SUN2000-4K-LB0,</u> <u>SUN2000-4.6K-LB0, SUN5000-3K-LB0</u>
Network connection rule	VDE-AR-N 4105:2018-11 “Generators connected to the low-voltage distribution network” Technical minimum requirements for connection and parallel operation of power generation systems connected to the low-voltage network	
Test requirement	DIN VDE V 0124-100 (VDE V 0124-100):2020-06 “Network integration of power generation systems – Low voltage” Test requirements for power generation units intended for connection to and parallel operation on the low-voltage network	
Test report	<u>64.290.24.30077.01</u> from <u>2024-11-12</u>	
The network and system protection designated above meets the requirements of VDE-AR-N 4105:2018-11.		

Certificate of Conformity

No. ESY 114387 0147 Rev. 00

E.7 Requirements for the test report for the NS protection

Extract from test report for NS protection			
“Determination of electrical properties”			
NS protection test report			
Type of NS system:	Integrated NS protection	Other Manufacturer indications	
Software version:	V300R024		
Manufacturer:	Huawei Digital Power Technologies Co.,Ltd. Office 01, 39th Floor, Block A, Antuoshan Headquarters Towers, 33 Antuoshan 6th Road, Futian District, 518043, Shenzhen, PEOPLE'S REPUBLIC OF CHINA		
Measuring period:	From 2024-09-17 to 2024-11-01		
		Inverter	
Protection function	Setting value	Tripping value	Tripping time NS protection*
Rise-in-voltage protection $U >>$	$1.25 * U_n$	L1-N: 287.64V	L1-N: 130.85ms
Rise-in-voltage protection $U >$	$1.10 * U_n$	$1.10 * U_n$	ms**
Voltage drop protection $U <$	$0.8 * U_n$	L1-N: 183.03V	L1-N: 3030.00ms
Voltage drop protection $U <<$	$0.45 * U_n$	L1-N: 102.08V	L1-N: 326.75ms
Frequency decrease protection $f <$	47.5 Hz	47.48Hz	162.05ms
Frequency increase protection $f >$	51.5 Hz	51.52Hz	150.50ms
*: The tripping time includes the period from the limit value violation U/f until the tripping signal to the interface switch.			
When planning the power generation system, the response time of the interface switch shall be added to the maximum time value obtained as indicated above.			
The disconnection time (sum of tripping time of the NS protection plus response time of the interface switch) shall not exceed 200 ms.			
**: Verification disconnection time of moving 10-min-average value.			
Disconnecting time as below:			
1. <u>460.50s</u> (L1-N from 600s@ U_n to 112% U_n)			
2. Continuous operation (L1-N from 600s@ U_n to 108% U_n)			
3. <u>262.80s</u> (L1-N from 600s@106% U_n to 114% U_n)			

Certificate of Conformity

No. ESY 114387 0147 Rev. 00

☒ as integrated NS protection	
Assigned to power generation unit type	<u>SUN2000-3K-LB0, SUN2000-3.68K-LB0, SUN2000-4K-LB0, SUN2000-4.6K-LB0, SUN5000-3K-LB0</u>
Integrated interface switch type	Series-connected relays for all phase conductors each Relay type: HF161F-40W/12-HTF
Response time of interface switch for integrated NS protection	Release time: Max. 10 ms
Verification of the entire functional chain "integrated NS protection – interface switch" has resulted in successful disconnection.	☒